Certificate Number 20171110 - EX15258 EX4141 - 19890214 **Report Reference**

Issue Date 2017-NOVEMBER-10

AMERICAN AVK CO Issued to:

2155 MERIDIAN BLVD

MINDEN, NV 89423-8601 USA

SAUDI VALVE MFG CO LTD **Manufacturer Company:**

INDUSTRIAL AREA PHASE 4

ROAD 404

PO BOX 10B30

JEDDAH 21 443 SAUDI ARABIA

This is to certify that representative samples of Gate Valves

Sizes (in.)	Rated Pressure (psig)
2-1/2, 3, 4, 6, 8, 10, 12	200
2-1/2, 3, 4, 6, 8, 10, 12	250
14, 16	200
2-1/2, 3, 4, 6, 8	250
	2-1/2, 3, 4, 6, 8, 10, 12 2-1/2, 3, 4, 6, 8, 10, 12 14, 16

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

UL 262 - Gate Valves for Fire-Protection Service. Standard(s) for Safety:

ULC/ORD-C262 - Gate Valves for Fire Protection Service.

Additional Information: See the UL Online Certifications Directory at


www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Chief Engineer, Global Inspection and Field Services





 Certificate Number
 20171110 - EX15258

 Report Reference
 EX4141 - 19890214

Issue Date 2017-NOVEMBER-10

Issued to: AMERICAN AVK CO

2155 MERIDIAN BLVD

MINDEN, NV 89423-8601 USA

Manufacturer Company: AVK POLSKA SP ZOO

UL JAKUBOWSKA 1

62-045 PNIEWY POLAND

This is to certify that representative samples of

Gate Valves

Model	Sizes (in.)	Rated Pressure (psig)
Series 25	2-1/2, 3, 4, 6, 8, 10, 12	200
Series 45	2-1/2, 3, 4, 6, 8, 10, 12	250
Series 45	14, 16	200
Series 145	2-1/2, 3, 4, 6, 8	250

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 262 - Gate Valves for Fire-Protection Service.

ULC/ORD-C262 - Gate Valves for Fire Protection Service.

Additional Information: See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC





Certificate Number 20171110 – EX15258

Report Reference EX4141 – 19890214

Issue Date 2017-NOVEMBER-10

Issued to: AMERICAN AVK CO

2155 MERIDIAN BLVD

MINDEN, NV 89423-8601 USA

Manufacturer Company: AMERICAN AVK CO

2155 MERIDIAN BLVD MINDEN NV 89423

This is to certify that representative samples of

Gate Valves

Model	Sizes (in.)	Rated Pressure (psig)
Series 25	2-1/2, 3, 4, 6, 8, 10, 12	200
Series 45	2-1/2, 3, 4, 6, 8, 10, 12	250
Series 45	14, 16	200
Series 145	2-1/2, 3, 4, 6, 8	250

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 262 - Gate Valves for Fire-Protection Service.

ULC/ORD-C262 - Gate Valves for Fire Protection Service.

Additional Information: See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, pleas contact a local UL Customer Service Representative at www.ul.com/contactus



Certificate Number 20171110 – EX15258

Report Reference EX4141 – 19890214

Issue Date 2017-NOVEMBER-10

Issued to: AMERICAN AVK CO

2155 MERIDIAN BLVD

MINDEN, NV 89423-8601 USA

Manufacturer Company: AVK INTERNAÏIONAL A/S

SMEDESKOWEJ 40

8464 GALTEN DENMARK

This is to certify that representative samples of

Gate Valves

Model	Sizes (in.)	Rated Pressure (psig)
Series 25	2-1/2, 3, 4, 6, 8, 10, 12	200
Series 45	2-1/2, 3, 4, 6, 8, 10, 12	250
Series 45	14, 16	200
Series 145	2-1/2, 3, 4, 6, 8	250

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 262 - Gate Valves for Fire-Protection Service.

ULC/ORD-C262 - Gate Valves for Fire Protection Service.

Additional Information: See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC







Certificate of Compliance

This certificate is issued for the following:

Fire Service Water Control Valves
OS&Y and NRS Gate Valves
Series 145 – Sizes 2-1/2, 3, 4, 6 and 8 inch NPS
(MODIFICATION)

Design

AVK Holding A/S Bizonvej 3, Skovby 8464 Galten Denmark

Manufacturing

American AVK Co. 2155 Meridian Blvd. Minden, NV 89423 United States

AVK Saudi Valves Manufacturing Co., Ltd. Phase 4, Street No. 404 Jeddah, Saudi Arabia 21443

> AVK Polska Ul Jakubowska 1 Pniewy, 62-045 Poland

FM Approvals Class: 1120/1130, dated April 1997

Approval Identification: 3059029 Approval Granted: October 13, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP - Manager, Fire Protection

FM Approvals

1151 Boston-Providence Turnpike Norwood, MA 02062 USA



Member of the FM Global Group